



Panel: Sub-Distribution Location: U-Centre 300 Level RM 304E
#1
FED From: Distribution #1 Voltage: 120/208 Amperage:
- RM 248Q

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
RTU #4 Billiard Room	60	3	1	A	2	3	100	RTU #3
RTU #4 Billiard Room	60	3	3	B	4	3	100	RTU #3 - Café Area
RTU #4 Billiard Room	60	3	5	C	6	3	100	RTU #3
Panel A	200	3	7	A	8	3	125	Degrees - Self Cooking Centre
Panel A - IQ Lounge	200	3	9	B	10	3	125	Degrees - Self Cooking Centre
Panel A	200	3	11	C	12	3	125	Degrees - Self Cooking Centre
			13	A	14	3		Panel NB
			15	B	16	3		Panel NB
			17	C	18	3		Panel NB
Panel SB	200		19	A	20	3	200	Panel HS
Panel SB	200		21	B	22	3	200	Panel HS
Panel SB	200		23	C	24	3	200	Panel HS
Panels SC+SJ	200		25	A	26		200	Panels TA+TB
Panels SC+SJ	200		27	B	28		200	Panels TA+TB
Panels SC+SJ	200		29	C	30		200	Panels TA+TB
	400		31	A	32		200	Panels FM+FL
	400		33	B	34		200	Panels FM+FL
	400		35	C	36		200	Panels FM+FL
			37	A	38		200	Panels FE+FC
			39	B	40		200	Panels FE+FC
			41	C	42		200	Panels FE+FC
			43	A	44		200	Panel TC
			45	B	46		200	Panel TC
			47	C	48		200	Panel TC



Panel: A

Location: IQ Lounge Back Closet

FED From: Sub-Distribution #1

Voltage: 120/208 Amperage: 100

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Fireplace Recept.	15	1	1	A	2	2	30	Espresso Machine
Fireplace Recept.	15	1	3	B	4	2	30	Espresso Machine
Receptacles	15	1	5	C	6			
Night + Emergency Lights	15	1	7	A	8	2	30	Espresso Machine
SPARE	50	2	9	B	10	2	30	Espresso Machine
SPARE	50	2	11	C	12	2	50	Dishwasher
Stereo Recept.	15	1	13	A	14	2	50	Dishwasher
Stereo Recept.	15	1	15	B	16			
Stereo Recept.	15	1	17	C	18	1	15	Freezer
			19	A	20	1	15	Coke Cooler
SPARE	15	1	21	B	22	1	15	Toaster
			23	C	24			
Lights	15	1	25	A	26	1	15	Fridge
Lights	15	1	27	B	28	1	15	Ice Maker
Lights	15	1	29	C	30	1	15	Fridge
Table USBs	15	1	31	A	32	1	15	LED Light Recepts.
Table USBs	15	1	33	B	34			
			35	C	36	1	15	TV Receptacles
Column Recepts.	15	1	37	A	38	1	15	TV Receptacles
Receptacles	15	1	39	B	40	1	15	TV Receptacles
	15	1	41	C	42	1	15	



Panel: Panel NB

Location: U-Centre 300 Level RM 310

FED From: Sub-Distribution #1

Voltage: 120/208 Amperage: 400

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Oven	50	3	1	A	22	2	15	
Oven	50	3	2	B	23	2	15	
Oven	50	3	3	C	24	1	30	
Kettle	70	3	4	A	25	3	60	Dishwasher
Kettle	70	3	5	B	26	3	60	Dishwasher
Kettle	70	3	6	C	27	3	60	Dishwasher
Coffee Maker	40	3	7	A	28	2	30	
Coffee Maker	40	3	8	B	29	2	30	
Coffee Maker	40	3	9	C	30	1	15	
RTU #1	70	3	10	A	31	1	15	
RTU #1	70	3	11	B	32	1	15	
RTU #1	70	3	12	C	33	1	15	
RTU #2	70	3	13	A	34	2	20	
RTU #2	70	3	14	B	35	2	20	
RTU #2	70	3	15	C	36	2	20	
	15	1	16	A	37	2	20	
	15	1	17	B	38	2	20	
			18	C	39	2	20	
Panel NA	100	3	19	A	40	3	100	Panel NK
Panel NA	100	3	20	B	41	3	100	Panel NK
Panel NA	100	3	21	C	42	3	100	Panel NK



Panel: Panel NA

Location: IQ Lounge Back Closet, 300 Level

FED From: Panel NB,
CCT's 19, 20, 21

Voltage: 120/208 Amperage: 100

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Counter Recept. - Food Prep	15	1	1	A	2	1	15	Grab + Go Cooler
Walk-In Cooler	15	2	3	B	4	1	15	Receptacle
Walk-In Cooler	15	2	5	C	6	1	15	
Cooler Prep Area Lights	15	1	7	A	8	1	15	SPARE
Counter Recept.	15	1	9	B	10	1	15	
Counter Recept.	15	1	11	C	12			
Counter Recept.	15	1	13	A	14	1	15	Display Case
	20	1	15	B	16	1	15	
Counter Recept.	20	1	17	C	18	1	15	
Counter Recept.	15	1	19	A	20	1	15	Undercut Pump Recept.
Counter Recept.	15	1	21	B	22			
SPARE	15	1	23	C	24			
Till Recept.	15	1	25	A	26			
Till Recept.	15	1	27	B	28			
Till Recept.	15	1	29	C	30			
Receptacles	15	1	31	A	32	2	30	Coffee Brewer
Receptacles	15	1	33	B	34	2	30	Coffee Brewer
Receptacles	15	1	35	C	36			
Counter Recept.	15	1	37	A	38			
Counter Recept.	15	1	39	B	40			
Washroom Door Operator	15	1	41	C	42			



Panel: Panel NK

Location: U-Centre 300 Level RM 310

FED From: Panel NB,
CCT's 40,41,42

Voltage: 120/208 Amperage: 100(225R8)

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Kitchen Lights	15	1	1	A	22	1	15	Dishwasher Exhaust Fan
Kitchen Lights	15	1	2	B	23	2	20	Toaster
Ref. Prep Unit	15	1	3	C	24	2	20	Toaster
Passover Shelf	15	1	4	A	25	2	30	Coffee Maker
Passover Shelf	15	1	5	B	26	2	30	Coffee Maker
Keg Receptacle	15	1	6	C	27	2	15	Espresso Machine
SPARE CCT in 12x12	15	2	7	A	28	2	15	Espresso Machine
Keg Recept.	15	2	8	B	29	1	15	SPARE in 12x12
Printer Recept.	15	1	9	C	30	1	15	SPARE in 12x12
Ref. Display Case	20	1	10	A	31	1	15	SPARE in 12x12
Till	20	1	11	B	32	1	15	SPARE in 12x12
Grinder	20	1	12	C	33	1	15	SPARE in 12x12
	15	1	13	A	34	1	15	
	15	1	14	B	35	1	15	
Keg Recept.	15	1	15	C	36	3	15	
Beer Cooler Recept.	15	2	16	A	37	3	15	
Beer Cooler Recept.	15	2	17	B	38	3	15	
Ref. Prep Unit	15	1	18	C	39	1	15	
	20	3	19	A	40	1	15	
	20	3	20	B	41	1	15	
	20	3	21	C	42			



Panel: Panel TA

Location: U-Centre 300 Level RM 310

FED From: Sub-Distribution #1

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Kitchen Lights	15	1	1	A	22	1	15	Corridor Lights
Counter Recept.	15	1	2	B	23	1	15	Corridor Lights
Counter Recept.	15	1	3	C	24	1	20	SPARE
Cooler Lights	15	1	4	A	25	1	15	
Cooler CU	30	2	5	B	26	1	15	Corridor Lights
Cooler CU	30	2	6	C	27	1	15	Neon Sign
Freezer CU	30	2	7	A	28	1	15	Corridor Lights
Freezer CU	30	2	8	B	29	1	15	Corridor Lights
Spare Above Freezer	30	2	9	C	30	1	20	Glycol Deck Recept.
Spare Above Freezer	30	2	10	A	31	1	15	Corridor Lights
SPARE	15	1	11	B	32	1	15	Corridor Lights
Exit Lights	15	1	12	C	33	1	15	Café IG Recept.
1 Q Piller Recept.	15	1	13	A	34	1	15	Café Coffee Machine
1 Q Piller Recept.	15	1	14	B	35	1	15	Café Planter Recept.
Spare Above Freezer	15	1	15	C	36	1	15	SPARE
Fan Above Freezer	15	2	16	A	37	3	15	Mixer
Fan Above Freezer	15	2	17	B	38	3	15	Mixer
L.V Lighting XFormer	15	1	18	C	39	3	15	Mixer
Billiard Rm Pot Lights	15	1	19	A	40	2	30	Spare - Beausiesior Rm
Billiard Rm Pot Lights	15	1	20	B	41	2	30	Spare - Beausiesior Rm
Billiard Rm Pot Lights	15	1	21	C	42	1	15	Spare - Beausiesior Rm



Panel: Panel TB

Location: U-Centre 300 Level RM 310

FED From: Sub-Distribution #1

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
CU 4th Flr. South	15	2	1	A	22	1	15	UMFM Track Lights
CU 4th Flr. South	15	2	2	B	23	1	15	UMFM Fluorescent Lights
CU 4th Flr. South	20	3	3	C	24	1	15	UMFM Recept.
CU 4th Flr. South	20	3	4	A	25	1	15	UMFM Lights + Recept.
SPARE	20	3	5	B	26	1	15	UMFM Fluorescent Lights
RM 352 Force Flow Heat	15	1	6	C	27	1	15	Spare in 6x6
3rd Floor Fan Heat	30	2	7	A	28	1	15	VAV 24V XFormer
3rd Floor Fan Heat	30	2	8	B	29	1	15	Spare in 6x6
Closet Heater	30	2	9	C	30	1	15	Recept.
Closet Heater	30	2	10	A	31	1	15	Recept.
Washroom Door Operator	15	1	11	B	32	1	15	Recept.
Bathroom B. Bank N.L	15	1	12	C	33	1	15	
3rd Floor Closet Fan	15	2	13	A	34	1	15	
3rd Floor Closet Fan	15	2	14	B	35	1	15	O.S. Pot Lights Photo Sensor
	20	1	15	C	36			
	15	1	16	A	37	1	15	
SPARE	15	1	17	B	38	1	15	
Area #2 Heat Cable	50	2	18	C	39	1	15	
Area #2 Heat Cable	50	2	19	A	40	1	20	
	15	1	20	B	41	1	20	Proofer
News IG Recept.	15	1	21	C	42	1	15	



Panel: Panel FM

Location: U-Centre 500 Level RM 502

FED From: Sub-Distribution #1

Voltage: 120/208 Amperage: 210

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
900W Corr. Night Lights	15	1	1	A	22	1	15	1000W Office Lights
1100W Corr. Lights	15	1	2	B	23	1	15	1100W Office Lights
900W Corr. Lights	15	1	3	C	24	1	15	1100W Office Lights
1000W Corr. Lights	15	1	4	A	25	1	15	Rm 500 Lights
900W Lobby Lights	15	1	5	B	26	1	15	
A - 750W Corr. Lights	A - 15	A - 1	6	C	27	1	15	900W Office Lights
B - Rm 500 TV Recept.	B - 15	A - 1						
600W Corr. Lights	15	1	7	A	28	1	15	1000W Office Lights
Corr. Night Lights	15	1	8	B	29	1	15	1000W Office Lights
	15	1	9	C	30	1	15	Exit Lights
1000W Office Lights	15	1	10	A	31	1	15	
800W Office Lights	15	1	11	B	32	1	15	Rm 503 Spec. Recept.
800W Office Lights	15	1	12	C	33	1	15	Rm 500A Recept.
800W Office Lights	15	1	13	A	34	1	15	
800W Office Lights	15	1	14	B	35	2	15	Womens Wash. Rm Hand Dryer
1000W Office Lights	15	1	15	C	36	2	15	Womens Wash. Rm Hand Dryer
1200W Washroom Lights	15	1	16	A	37	2	15	Handicap Hand Dryer
800W Office Lights	15	1	17	B	38	2	15	Handicap Hand Dryer
850W Office Lights	15	1	18	C	39	1	15	Rm 500A Recept.
600W Office Lights	15	1	19	A	40	1	15	
1200W Office Lights	15	1	20	B	41	A - 1	A - 15	A - Rm 505 Printer
						B - 1	B - 15	B - Rm 505 Fridge
450W Office Lights	15	1	21	C	42	A - 1	A - 15	A - Rm 505 Office Recepts.
						B - 1	B - 15	B - Rm 503, 503A Office Recepts.



Panel: Panel FL

Location: U-Centre 500 Level RM 502

FED From: Sub-Distribution #1

Voltage: 120/208 Amperage: 210

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Office Recepts	15	1	1	A	22	A - 1	A - 15	A - Rm 500 Floor + Wall Recepts
						B - 1	B - 15	B - Rm 500+B Floor + Wall Recepts
Rm 505 Recept	15	1	2	B	23	1	15	Rm 500A Water Cooler Plug + Exhaust
Rm 505 Recept	15	1	3	C	24	1	15	Drink Fountain
Rm 505 Recept	15	1	4	A	25	2	30	30A 2P Hot Truck Recept
Rm 511 Recept	15	1	5	B	26	2	30	30A 2P Hot Truck Recept
	15	1	6	C	27	A - 1	A - 15	A - Rm 500K Recept
						B - 1	B - 15	B -
S - Corridor Recepts	15	1	7	A	28	1	15	
Office Recepts	15	1	8	B	29	1	15	
Office Recepts	15	1	9	C	30	1	15	Rm 503 Wall Recept
A - Telephone Stor. 5-85	A - 20	A - 1	10	A	31	1	15	Rm 503 Wall Recept
B - Rm 508 Copier	B - 20	B - 1						
A - Serv. Outlet	A - 15	A - 1	11	B	32	A - 1	A - 15	A - Rm 500 K+J Recepts
B - Rm 511 Copier	B - 15	B - 1				B - 1	B - 15	B - Rm 500 H+G Recepts
Office Recepts	15	1	12	C	33			
Office Recepts	15	1	13	A	34	1	15	Rm 500 Door Operator
Office Recepts	15	1	14	B	35	1	15	Rm 500 Wall Recept
Office Recepts	15	1	15	C	36	1	15	Rm 500 Counter Recept
Office Recepts	15	1	16	A	37	1	15	Rm 500 Counter Recept
Office Recepts	15	1	17	B	38	1	15	Rm 505 Copier
Office Recepts	15	1	18	C	39	1	15	Rm 505 Recepts
Office Recepts	15	1	19	A	40	1	15	Rm 500J North Wall Recepts
Rm 500 A+J Copier Recept	20	1	20	B	41	A - 1	A - 15	A - Rm 500J Comp. Recepts
						B - 1	B - 15	B -
	15	1	21	C	42	A - 1	A - 20	A - Rm 500 G+H Comp Recepts
						B - 1	B - 20	B - Rm 500 G Copier



Panel: Panel FE

Location: U-Centre 400 Level RM 401A

FED From: Sub-Distribution #1

Voltage: 120/208 Amperage:

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
A - Rm. 418 Power	A - 20	A - 1	1	A	22	A - 1	A - 15	A - Spare in Degrees
B - Kitchen Recepts	B - 15	B - 1				B - 1	B - 15	B -
A - Rm. 413,414,417 Power	A - 15	A - 1	2	B	23	1	15	Rm. 400E Recept
B - Microwave	B - 15	B - 1						
A - Rm. 408,413,422 Power	A - 15	A - 1	3	C	24	A -	A - 15	A - Rm. 400E IG Recept
B - Fridge	B - 15	B - 1				B -	B - 15	B -
A - Rm. 415,417,419 Recepts	A - 15	A - 1	4	A	25	1	15	
B - Furniture Reception Area	B - 15	B - 1						
A - Rm. 406,413,415 Recepts	A - 15	A - 1	5	B	26	A - 1	A - 15	A - Rm. 400L Fans
B - Furniture Reception Area	B - 15	B - 1				B - 1	B - 15	B -
Rm. 496,497 Power	15	1	6	C	27	1	15	
Rm. 406,410,411 Power	15	1	7	A	28	A - 1	15	A - Cardac Recept
						B - 1	15	B - Exit Lights, Auto Toilets + Sinks
Rm. 405,406 Power	15	1	8	B	29	1	15	Rm. 491,409 Power
Rm. 409 Corr. Power	15	1	9	C	30	1	15	Rm. 416,415 Power
Rm. 483,484,485 Power	15	1	10	A	31	1	15	Rm. 416,415 Power
Rm. 485,487,488 Power	15	1	11	B	32	1	15	Rm. 415,411,409 Power
Rm. 492 Power	15	1	12	C	33	1	15	Rm. 400 Self Help Desk Recept
Rm. 479,481,482 Power	15	1	13	A	34	1	20	Rm. 424E Recept
Rm. 478,479 Power	15	1	14	B	35	1	15	Rm. 401 Comp. Recept
Rm. 476,477,492,Corr., 459,486 Power	15	1	15	C	36	1	20	
4th Flr. Women's Washrm Door Operator	15	1	16	A	37	1	15	Rm. 400B Recept
Washroom Recepts, Fountain	15	1	17	B	38	1	15	Rm. 400 Monitor TVSS
Rm. 472 Power	15	1	18	C	39	1	20	Rm. 400 Copier Recept
Rm. 468,470,471,480 Power	15	1	19	A	40	A - 1	A - 15	A - Rm. 400E Split Plug
						B - 1	B - 15	B - Rm. 400E Split Plug
Rm. 400P Copier	15	1	20	B	41	A - 1	A - 20	A - Rm. 406 Xerox Recept
						B - 1	B - 20	B - Rm. 421A Xerox Recept
A - Rm. 472,474,400P Power	A - 15	A - 1	21	C	42	A - 1	A - 15	A - Rm. 400E Printer Recept
B -	B - 15	B - 2				B - 1	B - 15	B - Rm. 400L Recepts



Panel: Panel FC

Location: U-Centre 400 Level RM 401A

FED From: Sub-Distribution #1

Voltage: 120/208 Amperage: 210

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
A - Corr. 409 Night Lights	A - 15	A - 1	1	A	22	A - 1	A - 15	A - Rm. 470,481,482 Lights
B - Corr. 409 Lights	B - 15	B - 1				B - 1	B - 15	B - Corr. Lights
A - Corr. 409 Lights	A - 15	A - 1	2	B	23	A - 1	A - 15	A - Rm. 476,477,478,480 Lights
B - Corr. 409 Lights	B - 15	B - 1				B - 1	B - 15	B - Corr. Lights
A - Corr. 409 Lights	A - 15	A - 1	3	C	24	A - 1	A - 15	A - Rm. 469,475,486 Lights
B - Corr. 409 Lights	B - 15	B - 1				B - 1	B - 15	B - Rm. 471,472,473,474 Lights
A - Women's Washroom	A - 15	A - 1	4	A	25	A - 1	A - 15	A - Receptacles
B - Rm. 412,413,414 Lighting	B - 15	B - 1				B - 1	B - 15	B - Rm. 415,416 Lights
A - Men's Washroom	A - 15	A - 1	5	B	26	1	15	Receptacles
B - Storage + Pipe Chase	B - 15	B - 1						
A - Rm. 417,418 Lights	A - 15	A - 1	6	C	27	1	15	Recepts + Corr. Night Light
B - Rm. 496,497,403 Lights	B - 15	B - 1						
A - Rm. 400 Workstation 7+8	A - 15	A - 1	7	A	28	2	30	Rm. 400L 30A Rack Recept
B - Rm. 400 Workstation 5+6	B - 15	B - 1						
A - Rm. 400 Workstation 7+8	A - 15	A - 1	8	B	29	2	30	
B - Rm. 400 Workstation 5+6	B - 15	B - 1						
A - Rm. 400 Workstation 7+8	A - 15	A - 1	9	C	30	2	30	
B - Rm. 400 Workstation 5+6	B - 15	B - 1						
A - Rm. 400 Workstation 3+4	A - 15	A - 1	10	A	31	2	30	
B - Rm. 400 Workstation 1+2	B - 15	B - 1						
A - Rm. 400 Workstation 3+4	A - 15	A - 1	11	B	32	1	15	Rm. 410,411 Lighting
B - Rm. 400 Workstation 1+2	B - 15	B - 1						
A - Rm. 400 Workstation 3+4	A - 15	A - 1	12	C	33	1	15	Rm. 405,406 Lighting
B - Rm. 400 Workstation 1+2	B - 15	B - 1						
Rm. 460,461,464,465 Lights	15	1	13	A	34	1	15	402 Entry Lights, Lektrie Ver
Rm 400S Fridge Recept	15	1	14	B	35	1	15	LV XFRM Lektrie Ver
Lektrie Ver	15	1	15	C	36	1	15	Stair + Hall Lights
A - Rm. 400P Recept	A - 20	A - 1	16	A	37	2	15	Men's Hand Dryer
B - Rm. 400P Recept	B - 20	B - 1						
A - Rm. 400 Lights	A - 15	A - 1	17	B	38	2	15	
B - Rm. 400 Lights	B - 15	B - 1						
Rm. 400 Entrance Lights	15	1	18	C	39	2	15	Women's Hand Dryer
Rm. 400,401A Lights	15	1	19	A	40	2	15	
Rm. 485,487 Lights	15	1	20	B	41	1	15	Rm. 400J Recepts
Rm. 483,484 Lights	15	1	21	C	42	1	15	Rm. 400J, K-X Recepts



Panel: Panel TC

Location: U-Centre 300 Level RM 310

FED From: Sub-Distribution #1

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Cooking Line Recept.	15	1	1	A	22	3	40	MUA #1
Corr. Recept, TVSS Monitor Degrees	15	1	2	B	23	3	40	MUA #1
Cooking Line Recept.	15	1	3	C	24	3	40	MUA #1
Men's Washroom Lights	15	1	4	A	25	1	15	Beausesior Rm. Lights
Women's Washroom Lights	15	1	5	B	26	1	15	Beausesior Rm. Lights
Coffee Maker	30	2	6	C	27	1	15	Beausesior Rm. Lights
Coffee Maker	30	2	7	A	28	1	15	Canopy Lights
Ice Maker	15	1	8	B	29	1	15	Canopy Lights
Hot Food Station	20	1	9	C	30	1	30	Holding Cabinet
Spare in 12x12	15	1	10	A	31	3	40	EF #1
Energy MGMT Centre	15	1	11	B	32	3	40	EF #1
Book Exchange Recept	15	1	12	C	33	3	40	EF #1
Elect. Rm. Recept	15	1	13	A	34	3	15	EF #2
	15	1	14	B	35	3	15	EF #2
L.V. XFormer	15	1	15	C	36	3	15	EF #2
Spare in 12x12	15	1	16	A	37	1	15	Rm. 204 Globe Lights
Front Counter Recept	15	1	17	B	38	1	15	SPARE
Conv. Recept	15	1	18	C	39	1	15	Rm. 204 Globe Lights
IQ W.W. Recept	15	1	19	A	40	1	15	SPARE
IQ W.W. Recept	15	1	20	B	41	1	15	Rm. 204 Globe Lights
IQ Ceiling Recept	15	1	21	C	42	1	15	SPARE



Panel: Panel SJ

Location: RM 207A

FED From: Sub-Distribution #1

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Rm. 217 Recept	20	1	1	A	22	1	15	
Rm. 217 Recept	20	1	2	B	23	1	15	
	15	1	3	C	24	1	15	
	15	1	4	A	25	1	20	
A - Split 20A Recept	A - 20	A - 1	5	B	26	1	15	
B - Split 204 Recept	B - 20	B - 1						
A - Split 200 Recept	A - 20	A - 1	6	C	27	1	15	
B - Split 204 Recept	B - 20	B - 1						
Glass Washer	15	1	7	A	28	1	15	
Glass Washer	15	1	8	B	29	1	15	
Pot Lights	15	1	9	C	30	1	15	
Chandeliers	15	1	10	A	31	1	15	
Pot Lights	15	1	11	B	32	1	15	
Bar Lights	15	1	12	C	33	1	15	
A - Soup Table	A - 20	A - 1	13	A	34	1	15	
B - Cooler	B - 20	B - 1						
A -	A - 20	A - 1	14	B	35	1	15	
B - Cooler #2	B - 20	B - 1						
Bistro	15	1	15	C	36	1	15	
Bistro	15	1	16	A	37	1	20	
Bistro	15	1	17	B	38	1	15	ATM
	15	1	18	C	39	2	30	
	15	1	19	A	40	2	30	
	15	1	20	B	41	1	30	
	15	1	21	C	42	1	15	



Panel: Panel SC

Location: RM 207A

FED From: Sub-Distribution #1

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
	15	1	1	A	22	1	15	Corr. Pot Lights
	15	1	2	B	23	1	15	Corr. Pot Lights
	15	1	3	C	24	1	15	Corr. Pot Lights
	15	1	4	A	25	1	15	Corr. Pot Lights
	15	1	5	B	26	1	15	Corr. Pot Lights
	15	1	6	C	27	1	15	
	15	2	7	A	28	1	15	SPARE - 8x8 Box Outside Tim's
	15	2	8	B	29	1	15	SPARE - 8x8 Box Outside Tim's
	15	1	9	C	30	1	15	SPARE - 8x8 Box Outside Tim's
	15	1	10	A	31	1	15	
	15	1	11	B	32	1	15	
	15	1	12	C	33	1	15	
	15	1	13	A	34	1	15	
	15	1	14	B	35	1	15	
	15	1	15	C	36	1	15	
Hi-Bay Lights	15	1	16	A	37	1	20	Corr. 201 Drinking Fountain
Hi-Bay Lights	15	1	17	B	38	1	15	
	15	1	18	C	39	2	50	
	15	1	19	A	40	2	50	
	15	1	20	B	41			
	15	1	21	C	42			



Panel: Panel SB

Location: RM 207A

FED From: Sub-Distribution #1

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
	15	1	1	A	22	1	15	
ADO 215 Door Operator	15	1	2	B	23	1	15	Open Area Black Pendant
SPARE	15	1	3	C	24	1	20	Open Area Black Pendant
SPARE	15	1	4	A	25	1	15	Black Pendant/Globe Lights
	15	1	5	B	26	1	15	Black Pendant/Globe Lights
SPARE	15	1	6	C	27	1	15	
2nd Floor Exit Lights	15	1	7	A	28	1	15	Open Area Black Pendant
	15	1	8	B	29	1	15	Temp. Stair Light
	15	1	9	C	30	1	15	SPARE
Rm. 217 Pot Lights	15	1	10	A	31	1	15	
Rm. 217 Projector	15	1	11	B	32	1	15	
Rm. 217 Screen	15	1	12	C	33	1	15	
Pot Lights Outside Rm. 217	15	1	13	A	34	1	15	SPARE
SPARE	15	1	14	B	35	1	15	SPARE
SPARE	15	1	15	C	36	1	20	Open Area Black Pendant
	15	1	16	A	37	1	15	
Open Area Black Pendant	15	1	17	B	38	1	15	
Open Area Black Pendant	15	1	18	C	39	1	15	
Open Area Black Pendant	20	1	19	A	40	1	15	
Globe Lights	15	1	20	B	41			
	15	1	21	C	42	1	15	



Panel: Panel HS

Location: RM 514C

FED From: Sub-Distribution #1

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
	15	1	1	A	7	1	15	
	15	1	2	B	8	1	15	
	15	1	3	C	9	2	15	208V Recept
	15	1	4	A	10	2	15	208V Recept
	15	2	5	B	11	1	15	Rm. 514A Desk Recept
	15	2	6	C	12	1	15	
	15	1	13	A	28	3	40	Feed For Top of Panel HS
MN. Oper. Rm. Recepts	15	1	14	B	29	3	40	Feed For Top of Panel HS
Meeting Rm. Recepts	15	1	15	C	30	3	40	Feed For Top of Panel HS
Rm. 518 Above Counter Recept	15	1	16	A	31	1	15	
Tech. Rm. Desk Recept	15	1	17	B	32	1	15	
208V Recept	15	2	18	C	33	1	15	
208V Recept	15	2	19	A	34			
Rm. 518 Recepts	15	1	20	B	35			
Rm. 518 Recepts	15	1	21	C	36			
Audio Locker Recepts	15	1	22	A	37			
Audio Locker Recepts	15	1	23	B	38			
Lights	15	1	24	C	39			
	15	1	25	A	40			
	15	1	26	B	41			
	15	1	27	C	42			