



Panel: Sub-Distribution Location: U-Centre 300 Level RM 311  
#4

FED From: Voltage: 600 Amperage:

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
			1	A	2			
Panel TG			3	B	4			Panels FB+FF
			5	C	6			
			7	A	8			
Panel TF			9	B	10			Panels FJ+FK
			11	C	12			
			13	A	14			
Panel TE			15	B	16			Panel IG
			17	C	18			
			19	A	20			
Panel RS			21	B	22			AHU #301



Panel: Panel RS

Location: U-Centre 300 Level RM 310B

FED From: Sub-Distribution #4, Rm 311

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Outside Lights	15	1	1	A	19	1		Live Studio/Rack Rm. Lights
Outside Lights	15	1	2	B	20	1		Spare in Rack Rm.
	15	1	3	C	21	1		Spare in Rack Rm.
MCR IG Recept	15	1	4	A	22	1		Spare in Rack Rm.
UMSU Vision IG Recept	15	1	5	B	23	1		Spare in Rack Rm.
MCR IG Recept	15	1	6	C	24	1		
MCR IG Recept	15	1	7	A	25	1		ACR IG Recept
UMFM Conv. Recept	15	1	8	B	26	1		ACR IG Recept
UMFM Conv. Recept	15	1	9	C	27	1		UMSU Vision IG Recept
Live Studio IG Recept	15	1	10	A	28	1		UMSU Vision IG Recept
Control Rm. IG Recept	15	1	11	B	29	1		VAV 24V XFormer
Control Rm. IG Recept	15	1	12	C	30	1		UMSU VISION Lights/Hall Pts+Recept
Rack Rm. IG Recept	15	1	13	A	31	1		UMSU Vision Recepts
Rack Rm. IG Recept	15	1	14	B	32	1		UMSU Vision Ceiling Recept
Rack Rm. IG Recept	15	1	15	C	33	1		UMSU Vision Ceiling Recept
Rack Rm. IG Recept	15	1	16	A	34	1		Spare in 12x12
Live Studio Lights	15	1	17	B	35	1		Spare in 12x12
Control Rm. Lights	15	1	18	C	36	A - 1	A - 15	A -
						B - 1	B - 15	B - Rm. 310 Rack Recepts



Panel: Panel TE

Location: U-Centre 300 Level RM 311

FED From: Sub-Distribution #4, Rm 311

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Book Exchange Lights	15	1	1	A	22	1	15	Corr. 323 Lights
Book Exchange Lights	15	1	2	B	23	1	15	Rm. 325 Lights
Rm. 314,320 Lights	15	1	3	C	24	1	15	Rm. 318,319,324 Lights
Scholars Kitchen Lights	15	1	4	A	25	1	15	Book Exchange Lights
Scholars Café Lights	15	1	5	B	26	1	15	Rm. 313,323 Recepts
Corr. 316 Lights	15	1	6	C	27	1	15	Book Exchange Lights
Scholars Café Lights	15	1	7	A	28	1	15	339 Lounge Recepts
Scholars Café Lights	15	1	8	B	29	1	15	339 Lounge Recepts
Scholars Café Lights	15	1	9	C	30	1	15	Exit Lights
Scholars Café Lights	15	1	10	A	31	1	15	324 Recepts
Scholars Café Lights	15	1	11	B	32	1	15	322 Recepts
Scholars Café Lights	15	1	12	C	33	1	15	L.V. XFormer
Outside Canopy Lights	15	1	13	A	34	1	15	Book Exchange Lights
Outside Canopy Lights	15	1	14	B	35	1	15	Scholars Café Lights
Outside Lights	15	1	15	C	36	1	15	Scholars Café Lights
Rm. 339 Lights	15	1	16	A	37	1	15	Scholars Café Lights
Rm. 339 Lights	15	1	17	B	38	1	15	Scholars Café Lights
Rm. 339 Lights	15	1	18	C	39	1	15	Book Exchange Lights
Rm. 339 Lights	15	1	19	A	40	1	15	Book Exchange Lights
Outside Lights	15	1	20	B	41	1	15	Book Exchange Lights
Corr. 338 Lights	15	1	21	C	42	1	15	Book Exchange Lights



Panel: Panel TF

Location: U-Centre 300 Level RM 311

FED From: Sub-Distribution #4, Rm 311

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Lighting	15	1	1	A	22	1	15	Lighting
Lighting	15	1	2	B	23	1	15	Lighting
Chandelier	15	1	3	C	24	1	15	Lighting
Chandelier	15	1	4	A	25	1	15	Track Lighting
Lighting	15	1	5	B	26	1	15	Track Lighting
Lighting	15	1	6	C	27	1	15	Track Lighting
Lighting	15	1	7	A	28	1	15	Track Lighting
Lighting	15	1	8	B	29	1	15	Track Lighting
Sky Dome Light	15	1	9	C	30	1	15	Track Lighting
Conf. Rm. + Office Recepts	15	1	10	A	31	1	15	Music Rm. Pot Lights
	15	1	11	B	32	1	15	Fridge Recept
L.V. XFormer	15	1	12	C	33	1	15	Music Rm. Pot Lights
Lighting	15	1	13	A	34	1	15	Rm. 311 Recept
Lighting	15	1	14	B	35			
Lighting	15	1	15	C	36			
Lighting	15	1	16	A	37			
Chandelier	15	1	17	B	38			
Chandelier	15	1	18	C	39			
Lighting	15	1	19	A	40			
Lighting	15	1	20	B	41	1	15	
Lighting	15	1	21	C	42	1	15	Master Clock



Panel: Panel TG

Location: U-Centre 300 Level RM 311

FED From: Sub-Distribution #4

Voltage: 120/208 Amperage:

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Lighting	15	1	1	A	22	1	15	Lighting
Lighting	15	1	2	B	23	1	15	Lighting
Lighting	15	1	3	C	24	1	15	Lighting
Lighting	15	1	4	A	25	1	15	
Chandelier	15	1	5	B	26	1	15	
Chandelier	15	1	6	C	27	1	15	Chandelier
Lighting	15	1	7	A	28	1	15	Track Lighting
Lighting	15	1	8	B	29	1	15	
Lighting	15	1	9	C	30	1	15	
Lighting	15	1	10	A	31	1	15	
Lighting	15	1	11	B	32	1	15	
Lighting	15	1	12	C	33	1	15	
Lighting	15	1	13	A	34	1	15	
Lighting	15	1	14	B	35	1	15	
Chandelier	15	1	15	C	36	1	15	L.V. XFormer
Lighting	15	1	16	A	37	1	15	Rm. 309 Receptacles
Lighting	15	1	17	B	38			
Lighting	15	1	18	C	39			
Lighting	15	1	19	A	40			
Lighting	15	1	20	B	41	2	40	
Chandelier	15	1	21	C	42	2	40	



Panel: Panel FF

Location: U-Centre 400 Level RM 458

FED From: Sub-Distribution #4, Rm 311

Voltage: 120/208 Amperage: 225

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Rm. 418,421,422,424 Power	15	1	1	A	22	1	15	Study Booth
A - Rm. 425,428,429 Power	A - 15	A - 1	2	B	23	1	15	Study Booth
B - Rm. 263 Credenza	B - 15	B - 1						
Rm. 429,433 Power	15	1	3	C	24	1	15	Rm. 430,458 Power
Rm. 438,440 Power	15	1	4	A	25	1	15	Rm. 412 Xerox Plug
Rm. 438,440 Power	15	1	5	B	26	1	15	Rm. 427 Floor Plug
Rm. 434,435,436 Power	15	1	6	C	27	1	15	Rm. 427 Floor Plug
Rm. 423 Power	15	1	7	A	28	1	15	Rm. 427 Floor Plug
Rm. 445 Power	15	1	8	B	29	1	15	Rm. 427 Floor Plug
Rm. 445,446, Corr. 447 Power	15	1	9	C	30	2	50	Heating Cable
Rm. 451,452 Power	15	1	10	A	31	2	50	Heating Cable
Rm. Corr. 456,460,461 Power	15	1	11	B	32	1	20	Rm. 400 Q Shredder Recept
Rm. Corr. 464,465 Power	15	1	12	C	33			
Rm. 441,450 Power	15	1	13	A	34	A - 1	A - 20	A - Rm. 474 Copier Recept
						B - 1	B - 20	B - Rm. 400U Xerox Recept
Rm. 453,454 Power	15	1	14	B	35	1	15	
Rm. 457,458 Power	15	1	15	C	36	1	15	Rm. 472 Copier Recept
A - Rm. 462,463 Power	A - 20	A - 1	16	A	37	1	15	Rm. 452,472A Recepts
B - Xerox Plug	B - 20	B - 1						
Rm. 440,441,463,466 Power	15	1	17	B	38	1	15	Rm. 452,472A IG Recepts
Rm. 440,467 Power	15	1	18	C	39	1	15	Rm. 472 Under Table IG Recepts
A - Rm. Corr. 426,432	A - 15	A - 1	19	A	40	1	15	Rm. 472 Under Table IG Recepts
B - Smart Board	B - 15	B - 1						
Rm. 442 Power	15	1	20	B	41	1	15	Rm. 472 Help Counter, Rm. 472B Recepts
A - Rm. 463 Projector	A - 15	A - 1	21	C	42	1	15	
B - Rm. 468,468A	B - 20	B - 1						



Panel: Panel FB

Location: U-Centre 400 Level RM 458

FED From: Sub-Distribution #4, Rm 311

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Rm. 467,468 Lights	15	1	1	A	22	1	15	Corr. 439,443 Night Lights
Rm. 440 Lights	15	1	2	B	23	1	15	Rm. 421,422 Lights
Rm. 440 Lights	15	1	3	C	24	1	15	Rm. 424,425 Lights
Rm. 438 Lights	15	1	4	A	25	1	15	Rm. 428,429 Lights
Rm. 438 Lights	15	1	5	B	26	1	15	Rm. 433 Lights
Rm. 432,434,435,436 Lights	15	1	6	C	27	1	15	Low Voltage XFormer
Rm. 427 Lights	15	1	7	A	28	1	20	Rm. 400T Quad TVSS
Rm. 427,447 Lights	15	1	8	B	29	1	15	Rm. 400W Quad Counter Recept
Rm. 444 Lights	15	1	9	C	30	1	15	400G Corr. Cooler Recept
Rm. 442 Lights	15	1	10	A	31	1	20	Rm. 400T TVSS Recept
Rm. 458,462,463,466 Lights	15	1	11	B	32	1	20	Rm. 400 Printer Recept
Rm. 449,450,453,454, 457 Lights	15	1	12	C	33	1	20	Rm. 400 Door Operator
Rm. 446 Lights	15	1	13	A	34	1	20	Rm. 400T TVSS Recept
Rm. 445 Lights	15	1	14	B	35	1	15	Rm. 400 Quad Furniture Recept
Rm. 445 Lights	15	1	15	C	36	1	20	Rm. 459A,461 Quad Recept
Rm. 423 Lights	15	1	16	A	37	1	15	Rm. 400 Quad Furniture Recept
Rm. 423 Lights	15	1	17	B	38	2	20	
Rm. 415,419,420 Lights	15	1	18	C	39	2	20	
Exit Lights	15	1	19	A	40	1	15	Spare Above Rm. 471
Corr. 439,443 Lights	15	1	20	B	41	1	15	Rm. 471 Recepts
Corr. 439,443 Lights	15	1	21	C	42	1	15	Rm. 469 Recepts



Panel: Panel FJ

Location: U-Centre 500 Level RM 539

FED From: Sub-Distribution #4, Rm 311

Voltage: 120/208 Amperage: 210

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
	15	1	1	A	22	2	15	Rm. 541 Spare Ceiling JB
Rm. 537	15	1	2	B	23	2	15	Rm. 541 Spare Ceiling JB
	15	1	3	C	24	1	15	Rm. 541J Comp.
	15	1	4	A	25	1	15	Rm. 541J Comp.
	15	1	5	B	26	2	15	Men's Washrm Hand Dryer
	15	1	6	C	27	2	15	Men's Washrm Hand Dryer
	15	1	7	A	28	1	15	Rm. 541 South Centre
Computer	15	1	8	B	29	1	15	Rm. 541 South Centre
Rm. 541 Counter Receptacle	15	1	9	C	30	1	15	Rm. 541 Comp. Wall
Rm. 508,510,541 Recept	15	1	10	A	31	1	15	Rm. 541 North Centre
Rm. 541 Receptacles	15	1	11	B	32	1	15	Rm. 541 North Centre
Rm. 541 Receptacles	15	1	12	C	33	1	15	Rm. 541 Receptacle
Rm. 516 Receptacles	15	1	13	A	34	1	15	Rm. 541 IG Recept
Rm. 541 IG Recepts	15	1	14	B	35	1	15	Rm. 541 Receptacle
SPARE	15	1	15	C	36	1	15	Rm. 541 Receptacle
Rm. 540 IG Recepts	15	1	16	A	37	1	15	Rm. 536 Coffee Recept
	15	1	17	B	38	1	15	Rm. 536 A+B Recept
	30	2	18	C	39	1	15	Rm. 536A IG Recept
	30	2	19	A	40	1	15	Rm. 537 IG Recept
Rm. 536A Exhaust Fan	15	1	20	B	41	1	15	Rm. 537 Copier Recept
Rm. 541 Exhaust Fan	20	1	21	C	42	1	15	Rm. 538 IG Recept



Panel: Panel FK

Location: U-Centre 500 Level RM 539

FED From: Sub-Distribution #4, Rm 311

Voltage: 120/208 Amperage: 210

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
700W Corr. Night Lights	15	1	1	A	22	2	15	750W Office Lights
1000W Corr. Night Lights	15	1	2	B	23	2	15	600W Office Lights
1100W Corr. Lights	15	1	3	C	24	1	15	1200W Office Lights
1000W Corr. Lights	15	1	4	A	25	1	15	1200W Office Lights
1100W Washroom Lights	15	1	5	B	26	2	15	600W Storage Lights
	15	1	6	C	27	2	15	Exit Lights
800W Office Lights	15	1	7	A	28	1	15	
800W Office Lights	15	1	8	B	29	1	15	Buzzer Transformer
800W Office Lights	15	1	9	C	30	1	15	
800W Office Lights	15	1	10	A	31	1	15	
1200W Office Lights	15	1	11	B	32	1	15	
450W Corridor Lights	15	1	12	C	33	1	15	
1000W Office Lights	15	1	13	A	34	1	15	
800W Office Lights	15	1	14	B	35	1	15	
900W Office Lights	15	1	15	C	36			
800W Office Lights	15	1	16	A	37			
600W Office Lights	15	1	17	B	38			
600W Office Lights	15	1	18	C	39			
900W Office Lights	15	1	19	A	40			
Rm. 541 Lights	15	1	20	B	41			
Rm. 541 Lights	15	1	21	C	42			



Panel: Panel IG

Location: RM 332

FED From: Sub-Distribution #4

Voltage: 120/208 Amperage: 225

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Rm. 333 IG Recepts	15	1	1	A	22	A - 1	A - 15	A - Rm. 336 IG Recepts
						B - 1	B - 15	B - West IG Recepts
Rm. 339 IG Recepts	15	1	2	B	23	A - 1	A - 15	A - Rm. 336 IG Recepts
						B - 1	B - 15	B - South IG Recepts
Rm. 339 IG Recepts	15	1	3	C	24	A - 1	A - 15	A - Rm. 336 IG Recepts
						B - 1	B - 15	B - East IG Recepts
Rm. 339 IG Recepts	15	1	4	A	25	A - 1	A - 15	A - Rm. 336 IG Recepts
						B - 1	B - 15	B - East IG Recept
Rm. 339 IG Recepts	15	1	5	B	26	1	15	SPARE in Ceiling
Rm. 339 TVSS Recepts	15	1	6	C	27	1	15	SPARE in Ceiling
Rm. 340 IG Recepts	15	1	7	A	28	1	15	SPARE in Ceiling
Rm. 340 IG Recepts	15	1	8	B	29	1	15	Rm. 335 IG Recept
Rm. 340 IG Recepts	15	1	9	C	30	1	15	Rm. 335, Table 1 IG Recepts
Rm. 340 IG Recepts	15	1	10	A	31	1	15	Rm. 335, Table 1 IG Recepts
Rm. 340 IG Recepts	15	1	11	B	32	1	15	Rm. 335, Table 2 IG Recepts
Rm. 340 IG Recepts	15	1	12	C	33	1	15	Rm. 335, Table 2 IG Recepts
Rm. 340 IG Recepts	15	1	13	A	34	A - 1	A - 15	A - Rm. 335, Table 3 IG Recepts
						B - 1	B - 15	B - ADT, Cardac
Rm. 340 IG Recepts	15	1	14	B	35	A - 1	A - 15	A - Rm. 335, Table 3 IG Recepts
						B - 1	B - 15	B - CCTV Recepts
Rm. 340 IG Projector	15	1	15	C	36	A - 1	A - 15	A - Rm. 335, Table 4 IG Recepts
						B - 1	B - 15	B - Rm. 339 Recepts
Rm. 336 IG Projector	15	1	16	A	37	A - 1	A - 15	A - Rm. 335, Table 4 IG Recepts
						B - 1	B - 15	B - Rm. 335 Wiremold IG Recept
SPARE in Ceiling	15	1	17	B	38	A - 1	A - 15	A - Rm. 335, Table 5 IG Recept
						B - 1	B - 15	B - Rm. 335 Wiremold IG Recept
SPARE in Ceiling	15	1	18	C	39	A - 1	A - 15	A - Rm. 335, Table 5 IG Recept
						B - 1	B - 15	B - Rm. 335 Front Desk IG Recepts
SPARE in Ceiling	15	1	19	A	40	3	30	TVSS
SPARE in Ceiling	15	1	20	B	41	3	30	TVSS Projection
SPARE in Ceiling	15	1	21	C	42	3	30	TVSS