



Panel: Panel J

Location: RM 103F

FED From: Sub-Distribution #2

Voltage: 120/208 Amperage: 225

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
U-Centre Canopy Lights	15	1	1	A	22	1	15	
U-Centre Canopy Lights	15	1	2	B	23	1	15	
U-Centre Lights	15	1	3	C	24	1	15	
GPA Microwave + Cash Desk	15	1	4	A	25	1	15	
GPA Microwave + TV	15	1	5	B	26	1	15	
GPA Counter Display + GPA Cash	15	1	6	C	27	1	15	
	15	1	7	A	28	2	15	GPA Fresh Snack
	15	1	8	B	29	2	15	GPA Fresh Snack
	15	1	9	C	30	1	15	Stairs #12 Lights
	15	1	10	A	31	1	15	Stairs #12 Lights
	15	1	11	B	32	1	15	Stairs #12 Lights
GPA Sign	15	1	12	C	33	1	15	
GPA Receipt	15	1	13	A	34	1	15	U-Centre Lights
GPA Receipt	15	1	14	B	35	1	15	Rm. 103H Receipt
SPARE	15	1	15	C	36	1	15	Rm. 105 Receipt
GPA Cooler	15	1	16	A	37	1	15	Rm. 105 Receipt
105 Corr. Receipt	15	1	17	B	38	1	15	Rm. 105 Receipt
105 Corr. Receipt	15	1	18	C	39	1	15	Rm. 103 Receipt
Rm. 105A TV	15	1	19	A	40	1	15	Rm. 103E Receipt
	15	1	20	B	41	A - 1	A - 15	A - Rm. 103 Receipt
						B - 1	B - 15	B - Rm. 103 Receipt
	15	1	21	C	42	A - 1	A - 15	A - Rm. 103 Night Control
						B - 1	B - 15	B - Rm. 103L Receipt



Panel: Panel L

Location: RM 103F

FED From: Sub-Distribution #2

Voltage: 120/208 Amperage: 225

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
	15	1	1	A	22	1	15	Exit Lights + Night Lights
	15	1	2	B	23	1	15	Loading Ramp
	15	1	3	C	24	1	15	Corr. Lights
	15	1	4	A	25	1	15	Corr. Lights
	15	1	5	B	26	1	15	Corr. Pot Lights
	15	1	6	C	27			
GPA Track Lights	15	1	7	A	28	1	15	Lunch/Corr./Office Lights
GPA Track Lights	15	1	8	B	29	1	15	Rm. 101A,E,F,G Lights
GPA Track Lights	15	1	9	C	30	1	15	Art Gallery Lights
GPA Track Lights	15	1	10	A	31	1	15	U-Centre TVs
GPA Downlights + Office Lights	15	1	11	B	32	1	15	
Office Lights	15	1	12	C	33	1	15	
Walk-In Cooler Outdoor Unit	20	3	13	A	34	2	25	AC-1 UMSU
Walk-In Cooler Outdoor Unit	20	3	14	B	35	2	25	AC-1 UMSU
Walk-In Cooler Outdoor Unit	20	3	15	C	36	1	15	
	15	1	16	A	37	1	15	Walk-In Cooler Heat + Lights
	15	1	17	B	38	1	15	Walk-In Cooler Fan GPA
Rm. 103F Recept	15	1	18	C	39	1	15	Rm. 103N Server Rack
	100	3	19	A	40	1	15	Rm. 103N Server Rack
	100	3	20	B	41	1	15	
	100	3	21	C	42	1	30	



Panel: Panel N

Location: RM 107A

FED From: Sub-Distribution #2

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Hallway Recept	15	1	1	A	22	1	15	Stair Lights
Post Office Recept	15	1	2	B	23	1	15	Under-Stair Light
Pharmacy Recept	15	1	3	C	24	1	15	GSA Office Recepts
Hallway Recept	15	1	4	A	25	1	15	GSA Office Recepts
Post Office IG Recept	15	1	5	B	26	1	15	SPARE
Pharmacy IG Recept	15	1	6	C	27	1	15	GSA Xerox Recept
Hallway Recept	15	1	7	A	28	1	15	Drink Machine E-Wall
Pharmacy Recept	15	1	8	B	29	1	15	Drink Machine E-Wall
Eye Glass Recept	15	1	9	C	30	1	15	Pharmacy Injection Fridge
Flower Shop	15	1	10	A	31	1	15	Drink Machine E-Wall
	15	1	11	B	32	1	15	
Telephone Recept	15	1	12	C	33	1	15	
SPARE	15		13	A	34	2	50	Hallway 50 Amp Recept
Pharmacy Vaccine Fridge	15	1	14	B	35	2	50	Hallway 50 Amp Recept
Force Flow 1-1	15	1	15	C	36	A - 1	A - 15	A - Panel Recept
						B - 2	B - 15	B -
Bookstore 50 Amp Recept	50	2	16	A	37	A - 2	A - 15	A - Panel Recept
						B - 1	B - 15	B -
Bookstore 50 Amp Recept	50	2	17	B	38	1	15	Insulin Fridge
Rm. 109 Counter Recept	15	1	18	C	39	A - 1	A - 20	A - Pharmacy Recept
						B - 1	B - 20	B -
Tunnel Recept	20	1	19	A	40	A - 1	A - 15	A - O/S Bookstore Recepts
						B - 1	B - 15	B - Column Recepts
A - Pharmacy Counter	A - 15	A - 1	20	B	41	A - 1	A - 15	A - O/S Bookstore Recepts
B - Force Flow 1-2	B - 15	B - 1				B - 1	B - 15	B - Column Recepts
A - Pharmacy Counter	A - 15	A - 1	21	C	42	A - 1	A - 15	A - O/S Bookstore Recepts
B - Force Flow 1-3	B - 15	B - 1				B - 1	B - 15	B - Column Recepts - Lounge Pit



Panel: Panel M

Location: RM 107A

FED From: Sub-Distribution #2

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Corr. Lights	15	1	1	A	22	2	20	Pharmacy HVAC Ductless
Corr. Lights	15	1	2	B	23	2	20	Pharmacy HVAC Ductless
Corr. Lights	15	1	3	C	24	1	15	Pharmacy HVAC Dampers
Exit Lights	15	1	4	A	25	1	15	Pharmacy Lights
BB-2 + BB-3	15	1	5	B	26	1	15	Pharmacy Lights
	15	1	6	C	27	1	15	Pharmacy Lights
Fireplace TV Recept	15	1	7	A	28	1	15	Pharmacy Lights
Fireplace	15	1	8	B	29	1	15	Pharmacy Lights
	15	1	9	C	30	1	15	Pharmacy Lights
Fire Side Lounge	15	1	10	A	31	1	15	Tunnel Lights
	15	1	11	B	32	1	15	Tunnel Lights
Corr. Lights	15	1	12	C	33	1	15	Corr. Lights
Corr. Lights	15	1	13	A	34	1	15	Mag. Door Holders - ENG
	15	1	14	B	35	1	15	
Post Office Sign	15	1	15	C	36	1	15	
	15	1	16	A	37	1	15	Travel Bureau Lights
	15	1	17	B	38	1	15	Travel Bureau Lights
Women's + HandiCap Washrm. Light	15	1	18	C	39	1	15	
Men's Washrm. Light	15	1	19	A	40	1	15	
Rm. 125 Lights	15	1	20	B	41	1	15	
			21	C	42	1	15	



Panel: Panel IGA

Location: RM 107A

FED From: Sub-Distribution #2

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
IG Recept	15	1	1	A	31	1	15	Bookstore POS
IG Recept	15	1	2	B	32	1	15	Bookstore POS
Exhaust Fan	15	1	3	C	33	1	15	Bookstore POS
CARDAC	15	1	4	A	34	1	15	Bookstore POS
IG Recept	15	1	5	B	35	1	15	Bookstore POS
	15	1	6	C	36	1	15	Bookstore Office
Rm. 107A Recept	15	1	7	A	37	1	15	Bookstore Office
	15	1	8	B	38	1	15	Rm. 419 TVSS 2R Recept
Rm. 125 TVSS Recept	15	1	9	C	39	1	15	Rm. 415 TVSS 2R Recept
Rm. 125 TVSS Recept	15	1	10	A	40	1	15	Rm. 415 TVSS 2R Recept
IG Recept	15	1	11	B	41	1	15	Rm. 419 TVSS 2R Recept
Rm. 125 Recept	15	1	12	C	42	1	15	Rm. 415 TVSS 2R Recept
	15	1	13	A	43	1	15	Rm. 415 TVSS 2R Recept
	15	1	14	B	44	1	15	Rm. 402 DDC Control
	15	1	15	C	45	1	15	Rm. 107A Rack Recept
	20	2	16	A	46	2	30	Rm. 107A Rack Recept
	20	2	17	B	47	2	30	Rm. 107A Rack Recept
Rm. 123 V/D Closet Recept	15	1	18	C	48	2	30	Rm. 107A Rack Recept
Rm. 123 V/D Closet Recept	15	1	19	A	49	2	30	Rm. 107A Rack Recept
	15	1	20	B	50	1	15	
	15	1	21	C	51	1	15	
Bookstore Security Gate	15	1	22	A	52	1	15	
	15	1	23	B	53	1	15	
Pharmacy Back Rm. Recept	15	1	24	C	54	1	15	
Recept Near Fireplace	15	1	25	A	55	1	15	
Column/TV Recept	15	1	26	B	56	1	15	
	15	1	27	C	57	1	15	
	30	3	28	A	58	1	15	
	30	3	29	B	59	2	30	
	30	3	30	C	60	2	30	



Panel: Panel K

Location: RM 103F

FED From: Sub-Distribution #2

Voltage: 120/208 Amperage: 225

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Rm. 101 Q,Z Recepts	15	1	1	A	22	1	15	
Rm. 101 R,Y Recepts	15	1	2	B	23	1	15	GPA Recept
Rm. 101 S,X Recepts	15	1	3	C	24	1	15	GPA Cooler
Rm. 101 T,W Recepts	15	1	4	A	25	1	15	GPA Cooler
Rm. 101 U,V Recepts	15	1	5	B	26	A - 1	A - 15	A -
						B - 1	B - 15	B -
Rm. 103 Recepts	15	1	6	C	27	1	15	COR 101Z HK Recept
Rm. 103 Recepts	15	1	7	A	28	1	15	GPA Cooler
Rm. 103 Recepts	15	1	8	B	29	1	15	GPA Recept
GPA Recept	15	1	9	C	30	1	15	Rm. 103H Recept
GPA Recept	30	2	10	A	31	1	15	
GPA Recept	30	2	11	B	32	1	15	GPA HK Recept
HK Recept	15	1	12	C	33	A - 1	A - 15	A -
						B - 1	B - 15	B -
GPA Recept	15	1	13	A	34	1	20	
Rm. 103B	15	1	14	B	35	1	15	
Cooler FL Recept	15	1	15	C	36	A - 1	A - 15	A -
						B - 1	B - 15	B -
Cooler 20A/240V Recept	20	2	16	A	37	1	20	
Cooler 20A/240V Recept	20	2	17	B	38	1	20	
GPA Cooler Recept	15	1	18	C	39	1	20	
GPA Floor Recept	15	1	19	A	40	1	20	
GPA Floor Recept	15	1	20	B	41	1	20	
GPA Cooler	15	1	21	C	42	1	20	



Panel: Panel S

Location: RM 103F

FED From: Sub-Distribution #2

Voltage: 120/208 Amperage: 225

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Rm. 101K,J Recepts	15	1	1	A	22	1	20	Rm. 101 Recepts
Rm. 101L,H Recepts	15	1	2	B	23	1	15	U-Centre Entry TV
Rm. 101G Recepts	15	1	3	C	24	1	15	Rm. 101 AA Recepts
Rm. 101G,F TV	15	1	4	A	25	1	15	Rm. 101 TV
Rm. 101F Recepts	15	1	5	B	26	1	15	Rm. 101 AA Recepts
Rm. 101F Recepts	15	1	6	C	27	1	15	Rm. 101 AA Recepts
Rm. 101E Recepts	15	1	7	A	28	1	15	Rm. 103P,Q,R,S Recepts
Rm. 101D Recepts	15	1	8	B	29	1	15	Rm. 103P,Q,R,S Recepts
Rm. 101D Recepts	15	1	9	C	30	1	15	Rm. 103M Recepts
Rm. 101N Recepts	15	1	10	A	31			A - UMSU Service Centre Recept
								B -
Rm. 101N Recepts	15	1	11	B	32			A - UMSU Service Centre Recept
								B - Rm. 101 AAA Recept
Rm. 101M Recepts	15	1	12	C	33			A - UMSU Service Centre Recept
								B - UMSU Service Centre Recept
HK Recepts	15	1	13	A	34	1	15	Rm. 103M Recepts
Rm. 101-M1 Recepts	15	1	14	B	35	1	15	Rm. 103M Recepts
Rm. 101O Recepts	15	1	15	C	36	1	15	Rm. 103M Recepts
Rm. 101O Recepts	15	1	16	A	37	1	15	Rm. 103M Recepts
Rm. 101P Recepts	15	1	17	B	38	1	15	SPARE
Rm. 101P Recepts	15	1	18	C	39	1	15	HVAC Control
Rm. 101 Fire Shutter	15	1	19	A	40	1	15	Crawlspace HP East
Rm. 101 Recepts	15	1	20	B	41			
Rm. 101 Recepts	15	1	21	C	42	1	15	Rm. 103P,Q,R,S Recepts



Panel: Panel Y

Location: RM 140

FED From: Sub-Distribution #2

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Rm. 138 Counter + Fridge Recept	15	1	1	A	22	2	15	Split Recept
2-100 Lounge Recepts	15	1	2	B	23	2	15	Food Counter
Rm. 138 Photocopier	15	1	3	C	24	1	15	Floor Recept
Rm. 138 Photocopier	15	1	4	A	25	2	15	Rm. 138 Microwave
Rm. 138 Desk Recept	15	1	5	B	26	2	15	Rm. 138 Microwave
Rm. 138 Desk Recept	15	1	6	C	27	1	15	SPARE
Rm. 138 Ceiling Recept	15	1	7	A	28	1	15	Office Recept
Recepts	15	1	8	B	29	1	15	Office Recept
Recepts	15	1	9	C	30	1	15	SPARE
Rm. 138 Desk Recept	15	1	10	A	31	1	15	Office Recept
Recepts	15	1	11	B	32	1	15	Office Recept
Photocopier	15	1	12	C	33	1	15	Sportswear Track Lights
Rm. 139 Recepts	15	1	13	A	34	1	15	Sportswear Track Lights
Rm. 139 Front Counter Recepts	15	1	14	B	35	1	15	Sportswear Track Lights
Rm. 139 Recepts	15	1	15	C	36	1	15	Hall Pot Lights
Recepts	15	1	16	A	37	1	15	Rm. 140E Recepts
Rm. 138 Desk Recept	15	1	17	B	38	1	15	Rm. 140D,A IG Recepts
IG Recepts	15	1	18	C	39	1	15	Rm. 140A IG Recepts
IG Recepts	15	1	19	A	40	1	15	Stage Outside Bookstore Lights
IG Recepts	15	1	20	B	41	1	15	SPARE
IG Recepts	15	1	21	C	42	1	20	Rm. 140A Xerox Recept



Panel: Panel P

Location: RM 123G

FED From: Sub-Distribution #2

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Rm. 125 Lights	15	1	1	A	22	1	15	Rm. 123A E-Wall Recept
Night Lights	15	1	2	B	23	1	15	Rm. 123A Lights
	15	1	3	C	24	1	15	Rm. 133 Hand Dryer
ATM Recept	15	1	4	A	25	1	15	
Rm. 123C Recept	15	1	5	B	26	1	15	Rm. 114P IG Recept
ATM Recept	15	1	6	C	27	1	15	SPARE in Crawlspace 6x6
Rm. 114P Recept	15	1	7	A	28	1	15	L-Shaped Island Recept
	15	1	8	B	29	1	15	Rm. 123A Island Recept
	15	1	9	C	30	1	15	Staff Rm. Lights
	15	1	10	A	31	1	15	Public Lights Crank Machine
	15	1	11	B	32	1	15	Teller Comp. Recept
	15	1	12	C	33	1	15	Rm. 123A Lights
Rm. 127 Hand Dryer	20	1	13	A	34	1	15	Rm. 123A IG Recept
Rm. 127 Hand Dryer	20	1	14	B	35	1	15	Rm. 123A E-Wall Recept
Rm. 127 Hand Dryer	20	1	15	C	36	1	15	
Rm. 131 Hand Dryer	20	1	16	A	37	1	15	
Rm. 131 Hand Dryer	20	1	17	B	38	1	15	
Rm. 133 Door Opener	15	1	18	C	39	1	20	
Panel PA	100	3	19	A	40	A - 1	A - 15	A -
						B - 1	B - 15	B - Rm. 125 Security Panel
Panel PA	100	3	20	B	41	A - 1	A - 15	A -
						B - 1	B - 15	B - Rm. 125 Recepts
Panel PA	100	3	21	C	42	A - 1	A - 15	A -
						B - 1	B - 15	B - Rm. 125 Recepts



Panel: Panel PA

Location: RM 123G

FED From: Panel P, CCTs
19,20,21

Voltage: 120/208 Amperage: 100

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Rm. 112 Recepts	15	1	1	A	2	1	15	
Rm. 114P Recepts	15	1	3	B	4	1	15	Comp. Recept
	15	1	5	C	6	1	15	
	15	1	7	A	8	1	15	
	15	1	9	B	10	1	15	Public Lights (ATM)
	15	1	11	C	12	1	15	SPARE
Rm. 112 Recepts	15	1	13	A	14	1	15	Rm. 114 IG Recept
Rm. 112 Recepts	15	1	15	B	16	1	15	Rm. 114 Lights
Rm. 112 Recepts	15	1	17	C	18	1	15	CIBC Sign
Focac Point Panel	70	3	19	A	20	1	15	
Focac Point Panel	70	3	21	B	22	1	15	Rm. 138 Recepts
Focac Point Panel	70	3	23	C	24	1	15	Rm. 114 IG Recept
Rm. 125 Hall Recept	20	1	25	A	26	1	15	
Rm. 125 Hall Recept	20	1	27	B	28	1	15	Rm. 114 IG Recept
Rm. 125 Hall Recept	20	1	29	C	30	1	15	Rm. 112 Sign
Rm. 125 Hall Recept	15	1	31	A	32	1	20	Rm. 112 Recepts
Rm. 125 Hall Recept	15	1	33	B	34	2	20	Rm. 112 Recepts
	15	1	35	C	36	2	20	Rm. 112 Recepts
	15	1	37	A	38	1	15	
	15	1	39	B	40	1	15	Comp. Repeater
	20	1	41	C	42	1	15	Water Fountain



Panel: Panel FP

Location: RM 121B

FED From: Panel PA

Voltage: 120/208 Amperage: 100

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Fluorescent Lights	15	1	1	A	2	1	15	Storage Quad Recept
Office/Storage Lights	15	1	3	B	4	1	15	Storage Quad Recept
Rm. 121 C,D Display Lights	15	1	5	C	6	1	15	Storage Recept
South Display Lights	15	1	7	A	8	1	15	Office Counter Quad Recept
North Display Lights	15	1	9	B	10	1	15	Office Counter Quad Recept
North Display Lights	15	1	11	C	12	1	15	Office Counter Recept
Comp. Recept	15	1	13	A	14	1	15	Office Quad Chair Recept
Wall Recept	15	1	15	B	16	1	15	Office Quad Chair Recept
Glasses Heater	15	1	17	C	18	1	20	Rm. 121D Equipment Recept 2R
Counter Recept by Panel	15	1	19	A	20	1	15	Rm. 121D Equipment Recept 1R
RM. 121,121C,D,H,K Recept	15	1	21	B	22	1	15	Rm. 121C Microwave
Rm. 121D Counter GFCI	15	1	23	C	24	1	15	Rm. 121C Fridge



Panel: ZZ ATM

Location: RM. 115

FED From: Sub-Distribution #2

Voltage: 120/208 Amperage: 225

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Receptacle	20	1	1	A	2	1	15	Lighting
Receptacle	20	1	3	B	4	1	15	Receptacle
Lighting	15	1	5	C	6	1	15	Receptacle
Receptacle	15	1	7	A	8	1	15	Receptacle
SPARE	15	1	9	B	10			
SPARE	20	1	11	C	12			
SPARE	20	1	13	A	14			
SPARE	20	1	15	B	16			
SPARE	15	1	17	C	18			
SPARE	15	1	19	A	20			
SPARE	15	1	21	B	22			
SPARE	15	1	23	C	24			
			25	A	26			
			27	B	28			
			29	C	30			