



Panel: Panel A - Lighting Location: Corr. 170

FED From: Sub-Distribution #3

Voltage: 120/208 Amperage: 225

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
A - Book Store Lights	A - 15	A - 1	1	A	22	A - 1	A - 15	A - Book Store Lights
B -	B - 15	B - 1				B - 1	B - 15	B -
Receiving Rm. 220V Recept	20	2	2	B	23	1	15	Book Store Lights
Receiving Rm. 220V Recept	20	2	3	C	24	1	15	Book Store Lights
A -	A - 15	A - 1	4	A	25	1	15	Office
B -	B - 15	B - 1						
Book Store Lights	15	1	5	B	26	1	15	Office
Book Store Lights	15	1	6	C	27	1	15	Office
A -	A - 15	A - 1	7	A	28	1	15	Book Store Lights
B - Receiving Rm. Recepts	B - 15	B - 1						
Book Store Lights	15	1	8	B	29	1	15	Office
Old Track Lights	15	1	9	C	30	1	15	Book Store Lights
Book Store Lights	15	1	10	A	31	1	15	Receiving Bell
Book Store Lights	15	1	11	B	32	1	15	Rm. 112 Office
Book Store Lights	15	1	12	C	33	1	15	Exit Lights
Loading Bay Lights	15	1	13	A	34	1	15	Unit Heaters 1-8
Book Store Lights	15	1	14	B	35	1	15	Unit Heaters 1-10,1-9
Book Store Lights	15	1	15	C	36	1	15	Waste Rm. Lights
Book Store Lights	15	1	16	A	37			
Book Store Lights	15	1	17	B	38			
Book Store Lights	15	1	18	C	39	A - 1	A - 15	A -
						B - 1	B - 15	B -
Book Store Lights	15	1	19	A	40	3	15	
Book Store Lights	15	1	20	B	41	3	15	
Lights	15	1	21	C	42	3	15	



Panel: Panel BA

Location: RM 004

FED From: Distribution
#1, Rm. 248Q

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Crawlspace Lights	15	1	1	A	22	1	15	Basement Recepts
Crawlspace Recepts	15	1	2	B	23	1	15	Basement Recepts
Crawlspace Lights	15	1	3	C	24	1	15	Basement Lights
Crawlspace Lights	15	1	4	A	25	1	15	Basement Lights
Crawlspace Recepts	15	1	5	B	26	1	15	Rm. 003+004
Crawlspace Lights	15	1	6	C	27	1	15	Rm. 003+004
Crawlspace Lights	15	1	7	A	28	1	15	Basement Lights
Crawlspace Lights	15	1	8	B	29	1	15	Basement Recepts
Crawlspace Lights	15	1	9	C	30	1	15	Basement Recepts
Crawlspace Lights	15	1	10	A	31	1	15	Basement Recepts
Crawlspace Recepts	15	1	11	B	32	1	15	Elevator Lights
Crawlspace Lights	15	1	12	C	33	1	15	Basement Recepts
Crawlspace Recepts	15	1	13	A	34	1	15	Basement Lights
Crawlspace Lights	15	1	14	B	35	1	15	Basement Lights
Crawlspace Lights	15	1	15	C	36	1	15	Crawlspace Lights
Crawlspace Lights	15	1	16	A	37	1	15	
Crawlspace Recepts	15	1	17	B	38	1	15	
Crawlspace Lights	15	1	18	C	39	1	15	
DDC Control	15	1	19	A	40	1	15	
	15	1	20	B	41	1	15	L.V Transformer
After Cooler	15	1	21	C	42	1	15	



Panel: Panel B

Location: Corr. 170

FED From: Sub-Distribution #3

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
SPARE	15	1	1	A	22	2	50	
Stair Lights	15	1	2	B	23	2	50	
L.V XFormer	15	1	3	C	24	1	15	Book Store Lights
Book Store Lights	15	1	4	A	25	1	15	Book Store Lights
Book Store Lights	15	1	5	B	26	1	15	Book Store Lights
Book Store Lights	15	1	6	C	27	1	15	Book Store Lights
Book Store Lights	15	1	7	A	28	1	15	Book Store Lights
Book Store Lights	15	1	8	B	29	1	15	Book Store Lights
Book Store Lights	15	1	9	C	30	1	15	Book Store Lights
Book Store Lights	15	1	10	A	31	1	15	Book Store Lights
Book Store Lights	15	1	11	B	32	1	15	Book Store Lights
Book Store Lights	15	1	12	C	33	A - 1	A - 15	A -
						B - 1	B - 15	B -
Book Store Lights	15	1	13	A	34	1	15	Stair Lights
Book Store Lights	15	1	14	B	35	1	15	Unit Heater 1-11
Book Store Lights	15	1	15	C	36	1	30	Compactor
Book Store Lights	15	1	16	A	37	3	15	Dock Levelers
Book Store Lights	15	1	17	B	38	3	15	Dock Levelers
Book Store Lights	15	1	18	C	39	3	15	Dock Levelers
Book Store Lights	15	1	19	A	40	3	20	Leveler
Book Store Lights	15	1	20	B	41	3	20	Leveler
Book Store Lights	15	1	21	C	42	3	20	Leveler



Panel: Panel BB

Location: RM 004

FED From: Distribution
#1, Rm. 248Q

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Basement Lights	15	1	1	A	22	2	70	Heating Cable
Basement Recepts	15	1	2	B	23	2	70	Heating Cable
Basement Lights	15	1	3	C	24	2	15	Heating Cable
Basement Lights	15	1	4	A	25	2	15	Heating Cable
Basement Recepts	15	1	5	B	26	3	30	Sump Pump #1
Stair #7 Lights	15	1	6	C	27	3	30	Sump Pump #1
Sump Pump #3	15	1	7	A	28	3	30	Sump Pump #1
Sump Pump #4	15	1	8	B	29	3	30	Sump Pump #2
Sump Pump #5	15	1	9	C	30	3	30	Sump Pump #2
Sump Pump #6	15	1	10	A	31	3	30	Sump Pump #2
Sump Pump #7	15	1	11	B	32	3	50	Welding Plug at Panel
Sump Pump #8	15	1	12	C	33	3	50	Welding Plug at Panel
Sump Pump #9	15	1	13	A	34	3	50	Welding Plug at Panel
Hot Water Circ. Pump	15	1	14	B	35			
	15	1	15	C	36			
Recirc. Pump #3	15	1	16	A	37			
Water Meters	15	1	17	B	38			
	15		18	C	39			
	15		19	A	40			
			20	B	41			
			21	C	42	1	15	CCMS Panel K-7 + Intellicon



Panel: Panel C

Location: RM 140U

FED From: Sub-Distribution #3

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
A - Rm. 138C,D,E Lights + Recepts	A - 15	A - 1	1	A	22	A - 1	A - 15	A - Bookstore Recept
B - Mailing Rm. Light 1	B - 15	B - 1				B - 1	B - 15	B - Change Rm. Lights
A - Rm. 138A,B Lights	A - 15	A - 1	2	B	23	A - 1	A - 15	A - Textbook Area Recepts
B - Lorna Office	B - 15	B - 1				B - 1	B - 15	B - Textbook Area Recepts
A - Lorna Office	A - 15	A - 1	3	C	24	A - 1	A - 15	A - Textbook Area Recepts
B - Lorna Office	B - 15	B - 1				B - 1	B - 15	B - Textbook Area Recepts
Office IG Recept 1408	15	1	4	A	25	1	15	Textbook Area Recepts
Office IG Recept 1408	15	1	5	B	26	1	15	Textbook Area Recepts
Office IG Recept	15	1	6	C	27	1	15	Textbook Area Recepts
Rm. 139 Lights	15	1	7	A	28	1	20	Photo Copier
Gen. Off. Lights	15	1	8	B	29	1	15	Column Recepts
Gen. Off. Lights	15	1	9	C	30	1	15	Force Flow 1-14+1-15
Gen. Off. Lights	15	1	10	A	31	A - 1	A - 15	A - Column Recepts
						B - 1	B - 15	B - Bookstore Recept
New SG Lights	15	1	11	B	32	1	15	Exit Lights
New SG Lights	15	1	12	C	33	1	15	Recepts
A - New SG Lights	A - 15	A - 1	13	A	34	3	15	Fan Force 1-14
B - Tech Lab Heater	B - 15	B - 2						
A - Tech Lab Heater	A - 15	A - 2	14	B	35	3	15	Fan Force 1-14
B - SPARE	B - 15	B - 1						
Tech Lab Heater	15	1	15	C	36	3	15	Fan Force 1-14
Panel CA	60	3	16	A	37	1	15	
Panel CA	60	3	17	B	38	A - 1	A - 15	A - Sec. Rm. IG Recept
						B - 1	B - 15	B -
Panel CA	60	3	18	C	39	A - 1	A - 15	A - Battery Bank Recept
						B - 1	B - 15	B -
A -	A - 15	A - 1	19	A	40	3	70	Panel CC
B -	B - 15	B - 1						
A -	A - 15	A - 1	20	B	41	3	70	Panel CC
B -	B - 15	B - 1						
	15	1	21	C	42	3	70	Panel CC



Panel: Panel CC

Location: RM 140U

FED From: Panel C, CCTs
40,41,42

Voltage: 120/208 Amperage: 70

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
SPARE	15	1	1	A	2	1	15	
Main Office Receipts	15	1	3	B	4	1	15	Accounting + Lunch Rm. Receipts
	15	1	5	C	6	1	15	Main Office Receipts
Cust. Serv. Lottery Receipt	15	1	7	A	8	1	15	Main Office Receipts
EBB-6	15	1	9	B	10	1	15	Acc/Mail/Tele/TextBook Receipts
Accounting Depot Receipt	15	1	11	C	12	1	15	Sporting Goods Cam. Receipt
Sporting Goods W.M Receipt	15	1	13	A	14	1	15	Acc + Office Receipts
Crawlspace Receipt - 3270 Syst.	15	1	15	B	16	1	15	Sporting Goods Track Lights
Sorting Area Receipt	15	1	17	C	18	1	15	Textbook Area Floor Receipts
Cash Receipt	15	1	19	A	20	1	15	Sorting Area Receipts
Text Book Area Receipt	15	1	21	B	22	1	15	Accounting Receipts
Comp. Serv. Receipt - Above Ceiling	15	1	23	C	24	1	15	Sporting Goods Exhaust
Cust. Serv. Receipts	15	1	25	A	26	1	15	Sporting Goods Lights
Front Cash Receipts	15	1	27	B	28	1	15	Front Cash + Cust. Serv. Receipts
Bookstore Counter IG Receipt	15	1	29	C	30	1	15	Temp. Cash Receipts
Security Sys. Receipt	15	1	31	A	32	1	15	Calc. Counter Receipt
Calc. Area Counter Receipt	15	1	33	B	34	1	15	Main Off. Receipts + Security Sys.
Sporting Goods Receipt	15	1	35	C	36	1	15	SPARE
Sporting Goods Receipt	15	1	37	A	38	1	15	Accounting Receipts
Main Office Receipt	15	1	39	B	40	1	15	Accounting + Tele. Rm. Receipts
Sporting Goods W.M Receipt	15	1	41	C	42	1	15	Main Office Receipts



Panel: Panel CA

Location: RM 140

FED From: Panel C, CCTs
16,17,18

Voltage: 120/208 Amperage: 100

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Lights	15	1	1	A	13	1	15	Rm. 140W Recept
Lights	15	1	2	B	14	1	15	Rm. 140W Lights
N-W Recepts	15	1	3	C	15	1	15	
N - IG Recepts	15	1	4	A	16	1	15	
N - Recepts	15	1	5	B	17			
S - Recepts	15	1	6	C	18			
Rm. 140 G,H IG Recepts	15	1	7	A	19			
Rm. 140H Lights + Recepts	15	1	8	B	20			
Rm. 140G Lights + Recepts	15	1	9	C	21			
Rm. 140 D,C Lights + Recepts	15	1	10	A	22			
Fax Machine Recept	15	1	11	B	23			
Rm. 140W IG Recept	15	1	12	C	24			



Panel: Panel SE

Location: RM 246

FED From: Sub-Distribution #3

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Rm. 203 Lights	15	1	1	A	22	1	15	Multi-Purpose MTG #3-2-11 Lights
Rm. 203 Lights	15	1	2	B	23	1	15	Multi-Purpose MTG #3-2-11 Lights
Rm. 203 Lights	15	1	3	C	24	1	15	Multi-Purpose MTG #3-2-11 Lights
Rm. 207 Lights	15	1	4	A	25	1	15	Exit Lights
Rm. 207 Lights	15	1	5	B	26	1	15	Stairway #10 Lights
Rm. 209 Lights	15	1	6	C	27	1	15	Stairway #10 Lights TC
Rm. 209 Lights	15	1	7	A	28	1	15	
Rm. 210 Lights	15	1	8	B	29	1	15	Outside Lights
Rm. 230H,J,K,236 Recepts	15	1	9	C	30	1	15	Rm. 230G,H IG Recepts
Rm. 230H,J Recepts	15	1	10	A	31	1	15	Rm. 230K,236 IG Recepts
Rm. 230G,H,J Recepts	15	1	11	B	32	1	15	Rm. 230J IG Recepts
Rm. 230J,K,236 Lights	15	1	12	C	33	2	70	
Multi-Purpose MTG #1-2-4 Lights	15	1	13	A	34	2	70	
Multi-Purpose MTG #1-2-4 Lights	15	1	14	B	35	3	20	
Multi-Purpose MTG #1-2-4 Lights	15	1	15	C	36	3	20	
Multi-Purpose MTG #1-2-4 Lights	15	1	16	A	37	3	20	
Multi-Purpose MTG #2-2-5 Lights	15	1	17	B	38			
Multi-Purpose MTG #2-2-5 Lights	15	1	18	C	39			
Multi-Purpose MTG #2-2-5 Lights	15	1	19	A	40			
Multi-Purpose MTG #2-2-5 Lights	15	1	20	B	41			
Multi-Purpose MG #3-2-11 Light	15	1	21	C	42			



Panel: Panel SH

Location: RM 246

FED From: Sub-Distribution #3, Rm.

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
2-94 Lounge Recepts	15	1	1	A	22	1	15	214 Emerg. Light Panel
2-100 Lounge Recepts	15	1	2	B	23	1	15	Force Flo Unit 2-66
2-97 Corr. Recepts	15	1	3	C	24	1	15	Force Flo Unit 2-65
2-03 Meeting Recepts	15	1	4	A	25	1	15	Force Flo Unit 2-62
2-04 Meeting Recepts	15	1	5	B	26	1	15	Force Flo Unit 2-61
2-07,2-09 Meeting Recepts	15	1	6	C	27	1	15	Unit Heater 2-1
2-08 Lounge Recepts	15	1	7	A	28	1	15	Women's Hand Dryer Rm. 231
2-07,2-09 Lounge Recepts	15	1	8	B	29	1	15	Women's Hand Dryer Rm. 231
2-10,2-15 Meeting Recepts	15	1	9	C	30	1	15	
2-11 Meeting Recepts	20	1	10	A	31	1	15	2-98 Recepts
Rm. 230H,G Lights	15	1	11	B	32	1	15	2-08 Lounge Recepts
2-14 Recepts	15	1	12	C	33	1	15	2-06 Corr. Recepts
2-85,2-86 Dining Recepts	15	1	13	A	34	A - 1	A - 15	A -
						B - 1	B - 15	B - Rm. 217A, 2-12 Counter Recepts
287,288 Recepts	20	1	14	B	35	A - 1	A - 15	A -
						B - 1	B - 15	B - Rm. 217A, 2-12 Counter Recepts
2-26 Storage Recepts	15	1	15	C	36	1	15	
2-26 Storage Recepts	15	1	16	A	37	A - 1	A - 15	A -
						B - 1	B - 15	B -
2-30 Storage Recepts	15	1	17	B	38	1	15	Women's Hand Dryer Rm. 231
2-32 Storage Recepts	15	1	18	C	39	1	15	Women's Hand Dryer Rm. 231
2-23 Janitor Recepts	15	1	19	A	40	1	20	Rm. 238 Copier
Drinking Fountain Recept	15	1	20	B	41	1	5	Temp. Rec. Rm.
Drinking Fountain Recept	15	1	21	C	42	A - 1	A - 15	A - Temp. Rec. Rm.
						B - 1	B - 15	B - RM. 221 Fridge



Panel: Panel SD

Location: RM 246

FED From: Sub-Distribution #4, Rm. 311

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Senior Lounge 2-94	15	1	1	A	22	1	15	Rm. 231B Men's W.R Light
Senior Lounge 2-94	15	1	2	B	23	1	15	2-18 Powder Light
Senior Lounge 2-94	15	1	3	C	24	1	15	RM. 231 Women's W.R Light
Senior Lounge 2-94	15	1	4	A	25	1	15	2-12 Corr. Light
Meeting Lounge 2-100	15	1	5	B	26	1	15	2-12 Corr. Light
Meeting Lounge 2-100	15	1	6	C	27	1	15	Rm. 230K,236 Recepts
Meeting Lounge 2-100	15	1	7	A	28	1	15	2-22 Storage Light
Meeting Lounge 2-100	15	1	8	B	29	1	15	2-24 Lined Storage
Meeting Lounge 2-100	15	1	9	C	30	1	15	Storage 2-26 1,TE
Stand-Alone Sign	15	1	10	A	31	1	15	
Rm. 221 Microwave	20	1	11	B	32	1	15	
Rm. 221 Microwave	20	1	12	C	33	1	15	
2-99 Storage Light	15	1	13	A	34	1	15	Travel Agency
			14	B	35	1	15	
	15	1	15	C	36	1	15	Rm. 211
2-06 Corridor Light	15	1	16	A	37	1	15	Rm. 211
2-21 Corridor Light	15	1	17	B	38	1	15	
2-21 Corridor Light	15	1	18	C	39	1	15	Men's Washrm Hand Dryer
Travel Agency	15	1	19	A	40	1	15	Women's Washrm Door Operator
Travel Agency	15	1	20	B	41			
	15	1	21	C	42	1	15	



Panel: Panel TH

Location: RM 338

FED From: Sub-Distribution
#4, Rm. 311

Voltage: 120/208 Amperage: 225

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Projection Booth Recept	15	2	1	A	22			
Projection Booth Recept	15	2	2	B	23			
Projection Booth Recept	15	2	3	C	24			
Projection Booth Recept	15	2	4	A	25			
Projection Booth Recept	15	1	5	B	26	1	20	Rm. 335A Recept
Projection Booth Recept	15	1	6	C	27	1	15	Rm. 335+335B
Projection Booth Recept	15	1	7	A	28	1	15	Rm. 335A,335B Lights
Rm. 338 Recept	15	1	8	B	29			
SPARE	15	1	9	C	30			
Rm. 338 Recepts	15	1	10	A	31			
Rm. 338 Recepts	15	1	11	B	32			
			12	C	33			
SPARE	15	1	13	A	34			
Rm. 335 Recepts	20	1	14	B	35			
Rm. 335 Recepts	20	1	15	C	36			
Rm. 335 Power Pole	20	1	16	A	37			
Rm. 335B TVSS Recept	15	1	17	B	38			
Rm. 335 Door Operator	15	1	18	C	39	2	40	
Rm. 335A Recepts	15	1	19	A	40	2	40	
Rm. 335A Recepts	20	1	20	B	41			
Rm. 335A Recepts	20	1	21	C	42			
	20	1	43	A	44			



Panel: Panel FA

Location: U-Centre 400 Level RM 424R

FED From: Sub-Distribution #3, Rm 218

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
426 Corr. Night Light	15	1	1	A	22	1	15	
426 Corr. Light	15	1	2	B	23	1	15	
Corr. Light	15	1	3	C	24	1	15	Rm. 424 P,S,T Lights
Corr. Light	15	1	4	A	25	1	15	L.V. Transformer
Rm. 410,411,414 Lights	15	1	5	B	26	1	15	Exit Light
Rm. 404,405,406 Lights	15	1	6	C	27	1	15	Rm. 424P Furniture Recepts
Rm. 417,418 Lights	15	1	7	A	28	1	15	Rm. 424P Furniture Recepts
Rm. 412,413 Lights	15	1	8	B	29	1	15	Rm. 424P Furniture Recepts
Rm. 407,408 Lights	15	1	9	C	30	1	15	Rm. 424P Furniture Recepts
Rm. 402,403 Lights	15	1	10	A	31	1	15	Rm. 424P Furniture Recepts
	15	1	11	B	32	1	15	Rm. 424P Furniture Recepts
	15	1	12	C	33			
Rm. 421 Lights	15	1	13	A	34			
Rm. 421 Lights	15	1	14	B	35			
Rm. 422,423,424 Lights	15	1	15	C	36			
Rm. 412 Lights	15	1	16	A	37			
Rm. 426,431 Lights	15	1	17	B	38			
Rm. 434,435 Lights	15	1	18	C	39			
Rm. 425,427,428 Lights	15	1	19	A	40			
Rm. 424 J,K,M Lights	15	1	20	B	41			
	15	1	21	C	42			



Panel: Panel FD

Location: U-Centre 400 Level RM 424R

FED From: Sub-Distribution #3, Rm 218

Voltage: 120/208

Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Rm. 421,422,423	15	1	1	A	22	1	15	Rm. 415,419,420,426 Corr.
Rm. 423,424,425	15	1	2	B	23	A - 1	A - 20	A - Rm. 424P Corr. Receipt
						B - 1	B - 15	B - 426 Corr. Fountain
Rm. 420 Floor Recepts	15	1	3	C	24	1	15	Rm. 410,411,414
Rm. 420,426	15	1	4	A	25	1	15	Rm. 406,410,426 Corr.
Rm. 426,431,433	15	1	5	B	26	1	15	Rm. 403,407,408, 412
A - Rm. 433,434	A - 15	A - 1	6	C	27	1	15	Rm. 413,417,418
B - Rm. 422A Quad Receipt	B - 15	B - 1						
A -	A - 15	A - 1	7	A	28	1	15	
B - Rm. 422A Quad Receipt	B - 15	B - 1						
A - Rm. 424P EF-1	A - 15	A - 1	8	B	29	A - 1	A - 20	A - Rm. 424S Printer Receipt
B - Rm. 424M EF-2	B - 15	B - 1				B - 1	B - 20	B -
A - Rm. 424M Fridge Plug	A - 15	A - 1	9	C	30	A - 1	A - 20	A - Rm. 424P Printer Receipt
B - Rm. 424M Counter Plugs	B - 15	B - 1				B - 1	B - 15	B - Rm. 424S Recepts + Clock
A - Rm. 424M Counter Plugs	A - 15	A - 1	10	A	31	1	15	Rm. 446 Microwave
B - Rm. 424M Microwave	B - 15	B - 1						
A - Rm. 424M Table Plugs	A - 15	A - 1	11	B	32	1	15	Rm. 446 Counter Plug
B - Rm. 424J Recepts	B - 15	B - 1						
A - Rm. 424K Recepts	A - 15	A - 1	12	C	33	1	15	Rm. 424 Hand Dryer
B - Rm. 446 Counter Plugs	B - 15	B - 2						
A - Rm. 446 Counter Plugs	A - 15	A - 2	13	A	34	1	15	Rm. 424 Hand Dryer
B - Rm. 424H Recepts	B - 15	B - 1						
Heating Cable	40	2	14	B	35	1	15	Rm. 424H Corr. Receipt
Heating Cable	40	2	15	C	36	1	15	Rm. 444 Split Receipt
Heating Cable	40	2	16	A	37	1	15	Rm. 444 Split Receipt
Heating Cable	40	2	17	B	38	1	15	Rm. 422 Furniture Receipt
Rm. 435,436	15	1	18	C	39	1	15	Rm. 424 Furniture Receipt
Rm. 436	15	1	19	A	40	1	15	Rm. 424 Furniture Receipt
Rm. 402,403	15	1	20	B	41	1	15	Rm. 422 N-Wall Quad Receipt
Rm. 404	15	1	21	C	42	1	15	RM. 422 S-Wall Receipt



Panel: Panel FG

Location: U-Centre 500 Level RM 525

FED From: Sub-Distribution #3, Rm 218

Voltage: 120/208 Amperage: 210

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Studio Receptacle	15	1	1	A	22	1	15	
Studio Receptacle	15	1	2	B	23	1	15	
Draft Studio Recept	15	1	3	C	24	1	15	
Draft Studio Recept	15	1	4	A	25	1	15	
Draft Studio Recept	15	1	5	B	26	1	15	
Draft Studio Recept	15	1	6	C	27	1	15	
Draft Studio Recept	15	1	7	A	28	1	15	
Draft Studio Recept	15	1	8	B	29	1	15	
Telephone Recept	15	1	9	C	30	1	20	Rm. 527 Recept
Office Recept	15	1	10	A	31	1	15	
Office Recept	15	1	11	B	32	1	15	
Office Recept	15	1	12	C	33	1	15	
Office Recept	15	1	13	A	34	1	15	Rm. 520C Recept
Rm. 527 Recept	15	1	14	B	35	A - 1	A - 15	A - Rm. 520C Recept
						B - 1	B - 15	B - Rm. 520B+C Recept
A -	A - 15	A - 1	15	C	36	A - 1	A - 15	A - Studio Receptacle
B - Rm. 523 Quad Recept	B - 15	B - 1				B - 1	B - 15	B - Rm. 520B+C Recept
A - Rm. 523 Quad Recept	A - 15	A - 1	16	A	37	1	15	
B -	B - 15	B - 1						
CJUM Tower Light (LEAVE ON)	15	1	17	B	38	2	15	Rm. 521B Quad Recept
	15	1	18	C	39	2	15	Rm. 521B Quad Recept
Draft Studio Recept	15	1	19	A	40	2	15	Rm. 524 Quad Recept
Draft Studio Recept	15	1	20	B	41	2	15	Rm. 524 Quad Recept
	15	1	21	C	42	1	15	Rm. 519 IG Recept



Panel: Panel FH

Location: U-Centre 500 Level RM 525

FED From: Sub-Distribution #3, Rm 218

Voltage: 120/208 Amperage: 210

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Studio Lighting	15	1	1	A	22	1	15	Exit Lighting
Studio Lighting	15	1	2	B	23	1	15	
Studio Lighting	15	1	3	C	24	1	20	Rm. 521D Counter Recept
Studio Lighting	15	1	4	A	25	1	20	Rm. 520N Counter Recept
Office Valence Lighting	15	1	5	B	26	1	15	Rm. 520N Counter Recept
Gen. Office Lighting	15	1	6	C	27	1	15	Rm. 520N Fridge Recept
Inter. Rm. Lighting	15	1	7	A	28	1	15	
Rm. 521 J,K,L,M Lighting	15	1	8	B	29	1	15	
Hallway Lighting	15	1	9	C	30	1	15	Rm. 519A,B,C Lighting
Meeting Rm. Lighting	15	1	10	A	31	1	15	Rm. 521J,K Lighting
Inter. Rm. 521H Lighting	15	1	11	B	32	1	15	Battery Bank
Inter. Rm. 521E,F Lighting	15	1	12	C	33	1	15	Inter. Rm. 521L,M Recept
	15	1	13	A	34	1	15	Rm. 520N GFCI
Studio Lighting	15	1	14	B	35	1	15	Rm. 520N Spare in Ceiling
Office Lighting	15	1	15	C	36	1	15	Meeting Rm. Recept
Office Lighting	15	1	16	A	37	1	15	Inter. Rm. 521L Recept
Office Lighting	15	1	17	B	38	1	15	Work Rm. Recept
Office Lighting	15	1	18	C	39	1	15	Copier Recept
Storage Room Lighting	15	1	19	A	40	3	60	
Office Lighting	15	1	20	B	41	3	60	Panel G
Office Lighting	15	1	21	C	42	3	60	



Panel: Panel TD

Location: U-Centre 300 Level RM 328

FED From: Sub-Distribution #4, Rm 311

Voltage: 120/208 Amperage: 200

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
A - Rm. 340 Fluorescent Lights	A - 15		1	A	22	1	15	Pub Receipts
B - Rm. 323 Fridge	B - 15							
A - Rm. 323 Microwave	A - 15		2	B	23	1	15	Pub Receipts
B - Fluorescent Lights	B - 15							
A - Rm. 340 Pot Lights	A - 15		3	C	24	1	15	Pub Receipts
B - F7+F8 Fans	B - 15							
Comp. Rm. 323B	15	1	4	A	25	1	15	Rm. 331,332 Lights
	15	1	5	B	26	1	15	Outside + Ext. Stairs Lights
Storage Lights	15	1	6	C	27	1	15	Rm. 331 CCMS Control
Rm. 331 Pub Lights	15	1	7	A	28	1	15	Meeting Rm. Receipts
Night Lights	15	1	8	B	29	1	15	Hall Receipts
Exit Lights	15	1	9	C	30	1	15	Comp. Rm. 323B
A - Rm. 339 Fluorescent Lights	A - 15	A - 1	10	A	31	1	15	Rm. 335 Fluorescent Lights
B - Rm. 326 B+C Receipts	B - 15	B - 1						
A - Rm. 339 Fluorescent Lights	A - 15	A - 1	11	B	32	1	15	Rm. 335 Fluorescent Lights
B - Rm. 326 A,B,E Receipts	B - 15	B - 1						
A - Rm. 339 Pot Lights	A - 15	A - 1	12	C	33	1	15	Rm. 335,336,340 Pot Lights
B - Rm. 326B Receipts	B - 15	B - 1						
A - Rm. 326 B,C,D Receipts	A - 15	A - 1	13	A	34	1	15	Rm. 336 Fluorescent Lights
B - Cardac System + A.D.T	B - 15	B - 1						
Hall Lights	15	1	14	B	35	1	15	Rm. 336 Fluorescent Lights
A - Outside Lights	A - 15	A - 1	15	C	36	1	15	Rm. 335,336 Fluorescent Lights
B - Rm. 326 Recept	B - 15	B - 1						
Meeting Rm. Lights	15	1	16	A	37	1	15	Rm. 336 Pot Lights
Storage Lights	15	1	17	B	38	1	15	Rm. 335 Pot Lights
Hall Lights	15	1	18	C	39	1	15	L.V. XFormer
Meeting Rm. Lights	15	1	19	A	40	3	70	Panel TJ
Meeting Rm. Lights	15	1	20	B	41	3	70	Panel TJ
Meeting Rm. Lights	20	1	21	C	42	3	70	Panel TJ



Panel: Panel G

Location: U-Centre 500 Level RM 525

FED From: Panel FH CCTs
40,41,42

Voltage: 120/208 Amperage: 60

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
A - Rm. 521 IG Recept	A - 15	A - 1	1	A	13	1	15	
B - Rm. 520A IG Recept	B - 15	B - 1						
A - Rm. 519 IG Recept	A - 15	A - 1	2	B	14	A - 1	A - 15	A - Rm. 519 IG Recept
B - Rm. 520P IG Recept	B - 15	B - 1						B - 1
A - Rm. 519 A/B IG Recept	A - 15	A - 1	3	C	15	A - 1	A - 15	A - Rm. 520B IG Recept
B - Rm. 519 IG Recept	B - 15	B - 1						B - 1
Rm. 519 A/B IG Recept	15	1	4	A	16	1	20	Rm. 520C IG Recept
Rm. 525 Rack Recept	30	2	5	B	17	1	15	Rm. 525 IG Rack Recept
Rm. 525 Rack Recept	30	2	6	C	18	1	15	SPARE
Rm. 525 Rack Recept	30	2	7	A	19	1	15	Rm. 525 IG Recept
Rm. 525 Rack Recept	30	2	8	B	20	A - 1	A - 15	A - Rm. 525 IG Recept
						B - 1	B - 15	B - Rm. 525 IG Rack Recept
Rm. 525 Rack Recept	30	2	9	C	21	1	15	Rm. 525 IG Recept
Rm. 525 Rack Recept	30	2	10	A	22	1	15	Rm. 520 Door Operator
Rm. 525 Rack Recept	30	2	11	B	23	2	20	Rm. 525 Rack Recept
Rm. 525 Rack Recept	30	2	12	C	24	2	20	Rm. 525 Rack Recept



Panel: Panel TJ

Location: RM 330

FED From: PNL TD, CCTs
40,41,42 Rm 328

Voltage: 120/208 Amperage:

Designation	Amps	Pole	CCT	Phase	CCT	Pole	Amps	Designation
Student Services Door Opener	15	1	1	A	22	2	30	Entrance Heater
Rm. 332 Recepts	15	1	2	B	23	2	30	Entrance Heater
Rm. 333 Recepts	15	1	3	C	24	1	15	Rm. 340 Projector
Rm. 332 Bench Recepts	15	1	4	A	25	1	15	Rm. 334 Recepts
Rm. 332 Bench Recepts	15	1	5	B	26	1	15	Rm. 334 Recepts
Rm. 335 Recepts	15	1	6	C	27	2	30	Rm. 323A Rack Recept
Rm. 335,336 Recepts	15	1	7	A	28	2	30	Rm. 323A Rack Recept
Rm. 339 Recepts	15	1	8	B	29	2	30	Rm. 323A Rack Recept
Rm. 336-340 Recepts	15	1	9	C	30	2	30	Rm. 323A Rack Recept
Rm. 340 Recepts	15	1	10	A	31	1	15	Rm. 339A TVSS Recept
Rm. 339 Recepts	15	1	11	B	32	1	15	Rm. 339A VAV
Rm. 335,336 Projector	15	1	12	C	33			
	15	3	13	A	34	A - 1	A - 15	A - Rm. 339A TVSS Recept
						B - 1	B - 15	B -
	15	3	14	B	35	2	20	Rm. 323A Rack Recept
	15	3	15	C	36	2	20	Rm. 323A Rack Recept
			16	A	37			
Beer Cooler Lights	15	1	17	B	38			
Beer Cooler Fan	15	1	18	C	39			
Beer Cooler Compressor	20	2	19	A	40			
Beer Cooler Compressor	20	2	20	B	41			
			21	C	42			